

THE POOLS OF THE CITY OF LOS ANGELES
Condition Report - July 2004



Council District 8
Algin Sutton Pool
8800 S Hoover St.
Los Angeles, CA 90044

Built: 1931
Capacity: 375 people

Summer of 2003:
The pool served 16,552 patrons.

Median Household Income of the Area:
\$18,906

Facility Hours Of Operation: 2004

Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
11AM TO 1PM 2PM TO 6PM	11AM TO 1PM 2PM TO 6PM	11AM TO 1PM 2PM TO 6PM	11AM TO 1PM 2PM TO 6PM	11AM TO 1PM 2PM TO 6PM	12PM TO 6PM	12PM TO 6PM	1PM-5PM

Programs:

Special Features:	SEASONAL POOL (OUTDOOR/ UNHEATED)
Programs:	SWIM LESSONS NOVICE SWIM TEAM INNERTUBE WATER POLO NOVICE SYNCHRONIZED SWIMMING JUNIOR LIFEGUARD TRAINING

The bathhouse was refurbished in 2000, and Recreation and Parks Facility Repair Division completed \$478,000 in repairs in 2002. Work encompassed installing a new surge pit and new piping to filter room. Decking was replaced where it had to be removed for pipe installation and a new stainless steel gutter system was installed. The facility is compliant with ADA. It was not evaluated during the infrastructure study.

Algin Sutton – Immediate Repairs Needed		
1	Paint and caulk pool tank	\$55,000
2	Filter room lighting	\$3,000
3	Pool heater	\$25,000
4	Replace chemical pumps	\$8,000
5	Refurbish bath house: paint (interior and exterior), plumbing fixtures, lighting, and partitions.	\$80,200
TOTAL		\$171,000

THE POOLS OF THE CITY OF LOS ANGELES
Condition Report - July 2004



Council District 8

Harvard Pool – CLOSED 2001

6120 Denker Avenue
Los Angeles 90047



Built: 1939

Capacity: 360 people

Median Household Income of the Area:
\$24,910

Out of service due to extensive leaks, probably tied to damage not detected immediately after the Northridge Earthquake. This pool had been rehabilitated in 1983. The area is high-need and the pool closure represents a hardship in the community. Work to design a new pool facility, which began in late 2002, is 75% complete, and led to a recent announcement of funding to demolish the old structure and construct a new family aquatic center and bathhouse building. Completion of design, the bidding process, and construction, will take approximately eighteen months. The new facility will meet ADA standards. Estimated cost: \$6 million

To Be Replaced
Funding Identified

THE POOLS OF THE CITY OF LOS ANGELES
Condition Report - July 2004



Council District 8
Van Ness Pool
5720 2nd Avenue
Los Angeles 90043

Built: 1959
Capacity: 360 people

Summer of 2003:
The pool served 20,166 patrons.

Median Household Income of the Area:
\$32,162

Facility Hours Of Operation: 2004

Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
11AM TO 5PM	11AM TO 5PM	11AM TO 5PM	11AM TO 5PM	11AM TO 5PM	12PM TO 6PM	12PM TO 6PM	1PM-5PM

Programs:

Facility Features:	SEASONAL POOL (OUTDOOR/ UNHEATED)
Sports Programs:	INNER TUBE WATER POLO NOVICE SWIM TEAM NOVICE SYNCHRONIZED SWIMMING
Other Programs:	JUNIOR LIFEGUARD TRAINING PROGRAM SWIM LESSONS (PRIVATE, SEMI-PRIVATE, PARENT/CHILD)

Due to the condition of the pool tank and leaks in the piping, this pool requires excessive water replacement in order to remain full, which also results in the need for increased chemical use. In addition to replacement of the tank and piping, the filter room needs to be replaced, and new chemical storage sheds should be installed. The bathhouse needs ADA upgrades and general refurbishment.

**#5 Priority
for Replacement**